

CERTIFICATE

Certificate holder

Studor Limited
Studor House
13 Sheridan Terrace, Hove
East Sussex
BN3 5AE
UNITED KINGDOM

Product

Air admittance valves for drainage systems

Type, Model

Maxi-Vent, KNITS II, OsmaVent 110

Testing basis

DIN EN 12380:2003-03
Certification scheme Air admittance valves for drainage systems (2003-10)

Mark of conformity



Registration No.

011-7B008

Valid until

2015-07-31

Right of use

This certificate entitles the holder to use the mark of conformity shown above in conjunction with the specified registration number.

See annex for further information.

2013-11-27

Robert Zorn M.Sc.
Managing Director

A handwritten signature in black ink, appearing to be 'RZ', is written over a horizontal line.



ANNEX

Page 1 of 1

Certificate

011-7B008 dated 2013-11-27

Technical Data

Designation: A I

Airflow capacity (250/101325 Pa):

DN 75 35,1 l/s

DN 90 35,2 l/s

DN 110 36,0 l/s

Airtightness tested at: 30/500/10000 Pa

Range of temperature: -40 °C to +60 °C

Effectiveness at temperatures below 0 °C: -40 °C

**Testing laboratory/
Inspection body**

BRE Ltd
Bucksnales Lane, Garston
Watford
WD259XX
UNITED KINGDOM

NSF International
Field Services
789 N. Dixboro Road
Ann Arbor MI 48113
USA

Test report(s)

Product test 660X001 dated 2010-07-08
Factory inspection 320386 dated 2009-09-21
Factory inspection 320386 dated 2011-11-10
Factory inspection 320386 dated 2012-11-28
Product test 288614 dated 2013-07-17
Product test 290796 dated 2013-10-18
Factory inspection 3203860 dated 2013-11-01